



A Division of SafeWorks, LLC
365 Upland Drive
Tukwila, Washington 98188-3801
Fax No.: (206) 575-6240
Phone No.: (206) 575-6445

Service Bulletin 04-006

Date: October 5, 2004
To: Branch Managers; Service Managers
From: Dave Romo & Gavin Brickell
cc: Distribution List
Subject: Step – Down Power Requirements

Summary

This bulletin is in regards to a branch request for information on how to convert a 208 – 240 three phase power source to a 208 – 230v. single phase.

This is a common application when using a rental platform or work cage for temporary use on tall buildings.

The options below are the only conversion methods approved by Spider Engineering.

Option # 1: The use of P.N. 8-0404 (Pigtail Conversion Assy;3Ø/1Ø).

Option # 2: When 110 volts single phase is required for the use of hand tools on a platform or work cage supplied with 208 – 240v. single phase: Use a step – down 220 /110 transformer with a wattage rating sufficient for your application, equipped with GFI protection.